

MILL TEST CERTIFICATE (copy provided by Tallowmere Steel Supply)

Certificate no. MTC-77310. Specification: ASTM A992 Grade 50

Heat lot number on this certificate: 44812

Product: W24x68 wide-flange beam

Chemical analysis (percent)

C 0.09 Mn 1.12 P 0.011 S 0.004 Si 0.22 Cu 0.18 V 0.04

Mechanical properties

Yield strength 54 ksi Tensile strength 71 ksi Elongation 23 percent

Remarks

Delivered with Shipment 3 under invoice INV-30418.

Note added by Larkspur receiving on June 30, 2025: stamp on the beams reads 44821. Does not match this certificate.

This is a fictional certificate created for the Discovery Triage sample case.